

February 4, 2009

LEDGEVIEW PRECAST CONCRETE, INC.
ALLEN E. FREUND
N6672 COUNTY TRUNK UU
FOND DU LAC WI 54937

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR, PUMP OR SEDIMENTATION
Model Number(s): 1000
(43.5" L.L., 23.4 GAL/IN.; 48 IN. MAX. DEPTH OF BURY; 488 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20090004

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of February 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Two inch PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal" gaskets.
 - Dual inlets at end of tank with an access opening above one inlet and an observation opening over the other inlet.
 - Bottom pipe openings for pump and holding tanks.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- **Tank bedding and burial depth: A minimum of 4 in. of ¾ in. clear stone overlying a firm uniform base. Bedding should be level around the perimeter and concave at the middle. For tank burial depths greater than 48 in., contact manufacturer for alternate installation instructions.**

This approval supersedes the approval issued on 2/7/2004 under product file number 20040011.

LEDGEVIEW PRECAST CONCRETE, INC.

Page 2

February 4, 2009

PRODUCT FILE NO. 20090004

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040011.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov